



Certificate No. : T-0071

# ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)  
ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33,

Fax : +91 (0265) 2638382




E-mail : erda@erda.org

Web : http://www.erda.org



## TEST REPORT

Sheet: 1 of 3

<b>NAME AND ADDRESS OF CUSTOMER</b>  TECHNITRON INDUSTRIES R-426, T.T.C, M.I.D.C, THANE-BELAPUR ROAD, RABALE, NAVI-MUMBAI-400 701.	<b>TEST REPORT NO.:</b> LIPS/112 <b>DATE :</b> 16/06/2011	
	<b>CUSTOMER REF. NO.:</b>	<b>DATE</b>
	TI/2011/0525-1	25/05/2011
	<b>DATE OF SAMPLE RECEIPT</b>	<b>DATE OF TESTING</b>
	25/05/2011	26/05/2011 to 27/05/2011
<b>SAMPLE DESCRIPTION</b>  <b>STARTER PANEL</b>  <b>Containing:</b> MCB-2 Nos., Contactor-1 No., O/L Relay-1 No., Push-Button-2 Nos., Lamp-2 Nos., Terminal- 1 Set.	<b>SAMPLE IDENTIFICATION</b>  <b>ERDA sample code no.:</b> LSWGWO0091927/01  Drg. No.: TI-11-05-20-2 (sheet 1 of 2) (Rev.0)  Sr. No. : Nil	
<b>TEST DETAILS</b>  1.0 IP 66 tests  <b>ENCLOSURES :</b> Drg. No.: TI-11-05-20-2 (sheet 1 of 2) (Rev.0)  <b>TEST WITNESSED BY :</b> Mr. Mahendra S. Yewale (Sr. Manager) of M/s. Technitron industries, Navi Mumbai.	<b>TEST SPECIFICATION</b>  IS/IEC 60529 - 2001	
<b>REMARKS:</b> Sample <b>conforms</b> to the requirement of IP 66 tests as per the standard.		
 <b>Prepared by</b>	 <b>Checked by</b>	 <b>Approved by</b>

- Note:**
1. This report relates only to the particular sample received for testing in good condition at ERDA.
  2. This report cannot be reproduced in part under any circumstances.
  3. Publication of this report requires prior permission in writing from Director, ERDA.
  4. Only the tests asked for by the customer have been carried out.

TE 0722183